

Major Ohio Application Requirements for Distributed Generation Interconnection

Review Level	Eligibility			Application / Contract	Review	Application Fees	Timeframe
Pre-Application	any project			applicant's informal request / discussion of information specified in 4901:1-22-04 (B)(1)	Pre-Application Review	none	varies
				applicant's formal written request / Pre-Application Report		\$300 processing fee	within 10 business days of the EDU receiving the applicant's written request and fee payment
1	<ul style="list-style-type: none"> » IEEE 1547 and UL 1741 compliance certified » inverter-based systems ≤ 25 kW 			Short Form Application / Standard Interconnection Agreement	Simplified Review	up to \$50 and may be waived	within 15 business days of the EDU notifying the applicant that it has received a complete interconnection service application
2	<ul style="list-style-type: none"> » IEEE 1547 and UL 1741 compliance certified » systems that are ineligible for Level 1 Review » system types not exceeding the limits identified below 			Standard Application / Standard Interconnection Agreement	Expedited Review	up to \$50, plus one dollar per kilowatt of system nameplate capacity	within 20 business days of the EDU notifying the applicant that it has received a complete Interconnection Service Application
	Line Voltage	Expedited Review Regardless of Location	Expedited Review on line capacity ≥ 600 amp and distance < 2.5 feeder miles from substation				
	≤ 5kV	≤ 500 kW	< 2 MW				
	> 5kV & ≤ 15 kV	≤ 2MW	< 3 MW				
	> 15 kV & ≤ 30 kV	≤ 3MW	< 4 MW				
> 30 kV & ≤ 69 kV	≤ 4MW	< 5 MW					
2 Supplemental	<ul style="list-style-type: none"> » systems reviewed under Level 2 and failed to meet the criteria but could possibly be interconnected consistent with safety, reliability, and power quality standards after minor modifications/further study 			applicant's written agreement within 15 days of EDU's offer to perform Supplemental Review / Standard Interconnection Agreement	Expedited Review including customized studies based on technical screens	\$2,500 deposit fee then adjusted to reflect actual costs of any engineering work done + actual cost of any minor modification of the EDU's system that would otherwise not be done but for the applicant's interconnection request	within 25 business days of the EDU receiving the Supplemental Review fee deposit
3	<ul style="list-style-type: none"> » not IEEE 1547 and UL 1741 compliance certified » all system types ≤ 20MW that are ineligible for/failed to pass Level 1 and Level 2 Review 			Standard Application or applicant's agreement to continue evaluating the application that fails the Supplemental Review criteria / Standard Interconnection Agreement	Standard Review including customized studies	up to \$100, plus two dollars per kilowatt of system nameplate capacity + actual cost of engineering work done as part of any customized study + actual cost of any modification of the EDU's system that would otherwise not be done but for the applicant's interconnection request - cost of Supplemental Review (if Level 3 evaluation is pursuant to Supplemental Review)	varies

*Note: See Interconnection Rules in Chapter 4901:1-22, Ohio Administrative Code for all technical requirements

Table last updated on: 01/17/2014